

CERTIFICATE ENEC/FI 2017042



Our Ref. 288669-1

Product	Electronic control gear for LED module
Rating and principal characteristics	220-240VAC; 0/50-60Hz; Constant current 900mA/12...50V or 1400mA/12...36V; tc +75°C; λ0,96; P-OUTmax: 50,4W; U-OUTmax: 60V; ta: -20...+50°C / -20...+40°C (built-in / independent); SELV; independent usage with LC1x70-SR cord anchorage
Trade mark (if any)	Helvar
Type	LC1x50 Active+
Name and address of the licensee and the manufacturer	Helvar Oy Ab Keilaranta 5 FI-02150 ESPOO FINLAND
Is in conformity with	EN 61347-2-13:2014 + A1:2017 EN 61347-1:2015 EN 62384:2006 + A1:2009
As shown in the Test Report(s) No(s)	288669-1A, 288669-1B
It is authorized to use of the marks	ENEC 16 and FI
Validity	This certificate is valid until 12 June 2022 provided that the Conditions for ENEC and FI certification are met. This certificate includes the right to use the ENEC 16 and FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.
Directive information	The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.
With the following limitations	-
Date of issue	12 June 2017
Signature	SGS Fimko Ltd Peter Fagerstedt Certification Manager



This certificate has 2 pages



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.