

CERTIFICATE ENEC/FI 2016065



Our Ref. 284744-1

Product Control unit for LED lighting and 3020004 ACTIVE+ sensor

Rating and principal characteristics ActiveAhead control unit: Tc 85°C, Ta -40°C ... 80 °C, IP20
3020004: Tc 50°C, Ta -20°C ... 50 °C, IP30

Trade mark (if any) Helvar

Type ActiveAhead control unit
3020004

Name and address of the licensee and the manufacturer Helvar Oy Ab
Keilaranta 5
FI-02150 ESPOO
FINLAND

Is in conformity with EN 61347-2-11:2001
EN 61347-1:2015

As shown in the Test Report(s) No(s) 284744-1

It is authorized to use of the marks ENEC 16 and FI

Validity This certificate is valid until 30 November 2021 provided that the Conditions for ENEC and FI certification are met. This certificate includes the right to use the ENEC 16 and FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.

Directive information The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

With the following limitations -

Date of issue 30 November 2016

SGS Fimko Ltd

Signature

Peter Fagerstedt

Certification Manager



This certificate has 2 pages



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.